

FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



| | |
|---------------------------------------|--------------------------------------|
| Item | Ball Valve |
| Size | 4" Full Bore, Flanged |
| Class | ANSI 300 |
| Part no. | AF74P-4466TG/300 |
| Body material | ASTM A216 WCB |
| Seat | PTFE |
| Manufactured by | Habonim Industrial Valves Ltd. |
| In accordance with job no. | 160838 COW |
| In accordance with drawing no. | 40-AF74P-4466TG-300 (dated 16/10/05) |

The above valve was tested by **Score (Europe) Ltd** at their **Specialised Valve Research and Test Centre, Cowdenbeath, Scotland** and the results have been recorded as a **PASS**, having complied with the minimum performance requirements stated in **specification**

BS EN ISO 10497:2004 Second Edition August
2004 & ANSI/API Specification 607 Fifth Edition, June 2005

| | |
|--|-------------------------------------|
| Test date | 15/02/06 |
| Other sizes qualified | 4", 5", 6", 8" |
| Other pressure ranges qualified | ANSI 300, 400, 600 & PN 40, 63, 100 |

Tested by W Hay / S. Penman

D. Wood 24/02/06

SCORE (GOWDENBEATH) TEL 01383 510510
QA INSPECTION

Witnessed by W. Campbell - Lloyds Register

Juleta
W. Campbell
Glasgow Office 24/02/06

Lloyd's Register EME
Lloyds Register

This certificate must be read in conjunction with the full **Score Test Report Number** 160838-2